



Voimalaitoksen polttoaineportfolion ja suorituskyvyn hallinta FuelDiet ratkaisun avulla

VGB-Valiokunnan (Suomi) ja Suomen
Automaatioseura ry:n
Voimalaitosjaoksen ”*Digitalisaation
mahdollisuudet voimalaitoksissa*”-
seminaari, 25.4.2017 Tampere

Jaani Silvennoinen
Valmet Technologies Oy

Sisällysluettelo

- 1 Johdanto
- 2 Tekninen kuvaus – mitä ja miksi tehtiin
- 3 Esimerkkejä kattilan FuelDiet[®] jatkuvasta seurannasta
- 4 Yhteenveto

Kummanko polttoaineen valitsisit?




Pb = 31 mg/kg DS
Cl = 3000 mg/kg DS
Ash = 18 wt-% DS



Pb = 110 mg/kg DS
Cl = 400 mg/kg DS
Ash = 1.9 wt-% DS


Production cost vs. technical challenge

Production cost



- The energy production cost split of a solid fuel fired thermal power plant.
- For unit size of 80 MW_{fuel} and annual operating time of 8000 hours fuel cost is about 9 MEUR (fuel price 14 €/MWh)

Technical challenge



FuelDiet

Technical description

Data sources


Process data

$p, T, flow$

Valmet fuel database



Plant fuel database





Algorithms

	Reference	FuelDiet 1	FuelDiet 2	FuelDiet 3
Fluidized bed behaviour	●	●	●	●
Slagging	●	●	●	●
Fouling at higher temperatures	●	●	●	●
Fouling at lower temperatures	●	●	●	●
High temperature corrosion	●	●	●	●
Furnace wall corrosion	●	●	●	●
Heavy metal induced corrosion	●	●	●	●
Emissions	●	●	●	●

+

Fuel conveying model

Realtime "fuel in the process" visualization



Technical pilots

Utility CHP plant


165 MW_{fuel}

130 bar

535 °C

Woody biomass, peat

CFB



Industrial CHP plant


80 MW_{fuel}

92 bar

523 °C


Woody biomass, peat and mill residues

BFB



Utility CHP plant-fuel feeding system

Fuel flow tracking model



Boiler FuelDiet # 1

Moisture, LHV_{wet}

Select snapshot time

26/02/2014 16:30:00

Fuel blend composition


Volume [m3]	25.5
Moisture (forecasted) [wt-%]	38.6
LHV wet (forecasted moisture) [MJ/kg]	11.9
Moisture (with full moisture info) [wt-%]	40.7
LHV wet (with full moisture info) [MJ/kg]	11.4
Ash [wt-%]	1.65
N [wt-%]	0.42
Na+K [wt-%]	0.13
S [wt-%]	0.03
Cl [wt-%]	0.02
S/Cl [molar]	1.30
Ca/S [molar]	13.13

Fuel blend in boiler

Fuel type	Source silo	Accuracy	vol [m3]
Kuori	Kuori	Good	15.9
Metsätähdehake	Turve	Good	4.0
Tehdas_muupuu	Factory		3.3
Tehdas_pöly	Factory		2.3
Tehdas_vanerinsyrjä	Factory		0.0

Select zoom range

12/01/2014 00:00:00 27/06/2014 23:59:59



Boiler FuelDiet # 2

Ash, Cl, N, Na+K

Select snapshot time

26/02/2014 17:00:00

Fuel blend composition

Volume [m3]	25.4
Moisture (forecasted) [wt-%]	38.6
LHV wet (forecasted moisture) [MJ/kg]	11.9
Moisture (with full moisture info) [wt-%]	40.7
LHV wet (with full moisture info) [MJ/kg]	11.4
Ash [wt-%]	1.65
N [wt-%]	0.42
Na+K [wt-%]	0.13
S [wt-%]	0.03
Cl [wt-%]	0.02
S/Cl [molar]	1.30
Ca/S [molar]	13.13


Fuel blend in boiler

Fuel type	Source silo	Accuracy	vol [m3]
Kuori	Kuori	Good	15.8
Metsätähdehake	Turve	Good	4.0
Tehdas_muupuu	Factory		3.3
Tehdas_pöly	Factory		2.3
Tehdas_vanerinsyrjä	Factory		0.0

Select zoom range

11/01/2014 00:00:00

26/06/2014 23:59:59



Fluidized bed sintering risk tracking

Select snapshot time
 10/08/2014 11:30:00

Agglo indicators


Volume [m3]	6.64
Moisture (forecasted) [wt-%]	21.73
LHV wet (forecasted moisture) [MJ/kg]	14.61
Agglo index	39.47
Na+K [wt-%]	0.17
S/Cl [molar]	1.57

Fuel blend in boiler

Fuel type	Source silo	Accuracy	vol [m3]
Metsätähdehake	Kuori	Good	1.8
	Turve	Good	0.7
Tehdas_pöly	Factory		2.3
Tehdas_vanerinsyrjä	Factory		1.1
Tehdas_muupuu	Factory		0.7

Select zoom range

01/08/2014 00:00:00 08/11/2014 23:59:59



Superheater corrosion risk tracking

Select snapshot time

26/02/2014 17:00:00

Corrosion indicators

Volume [m3]	25.4
Corrosion risk index (tertiary)	96.8
Corrosion rate (tertiary) [mm/yr]	0.4
Lifetime (tertiary) [years]	5.1
S/Cl [molar]	1.30
Steam temperature (tertiary)	520

Fuel blend in boiler

Fuel type	Supplier	Source silo	Accuracy	vol [m3]
Kuori		Kuori	Good	15.8
Metsätähdehake		Turve	Good	4.0
Tehdas_muupuu		Factory		3.3
Tehdas_pöly		Factory		2.3
Tehdas_vanerinsyrjä		Factory		0.0

Select zoom range

06/09/2013 10:00:00

31/08/2015 23:00:00

Tertiary superheater




Fuel moisture weekly overview

Measured moisture % of fuel loads

Load Name	supplier	Avg. Fuel Moisture	Min. Fuel Moisture	Max. Fuel Moisture	Distinct count..	
Metsähake	03	41.4	38	46.6	9	○
	15	45.1	36.1	62.1	9	○
	25	38.2	26.8	43.2	12	○
	31	48.4	39.4	58.6	43	○
	35	53.2	43.8	54.7	7	○
	61	52.3	52	52.9	8	○
Turve	82	43.4	36.1	53	5	○
	10	38.6	34.1	42.4	11	○
	21	42.1	29.1	47.3	16	○
	38	43.3	41.4	44.4	8	○
	61	44.6	41.9	46.9	14	○
Kantomurske metsä	_1	45.3	43.3	47.8	66	○
	_5	41.0	38.8	41.8	23	○
	03	36.4	35.8	37	4	○
	15	40.0	40	40	1	○
Puru	31	29.4	28	29.9	3	○
	35	38.8	36.6	41.3	23	○
	15	54.8	54.8	54.8	2	○
	20	54.8	54.8	54.8	1	○
Kutterin puru	21	57.4	56.3	61.1	6	○
	36	57.9	57.9	57.9	1	○
	41	54.9	52.2	58.1	5	○
Rankahake	29	13.9	10.3	22.3	8	○
Puru / Kuori	61	38.3	35.1	52.9	6	○
	82	38.1	37.5	38.6	2	○
Puru suo	15	58.6	57.5	59.6	12	○
Turvebriketti	20	51.8	36.4	59.2	5	○
	20	Null	Null	Null	1	○


Select Year
2015

Select week
Week 10



Fuel composition weekly overview

Fuel composition



Select Year

2015

Select Week

Week 10

Fuel volume, flow and energy content

	Week 10
Volume [m3]	27,034
Dry weight [t]	4,496
LHV wet [MJ/kg]	9.8
Fuel energy [GWh]	6,135
Average boiler [MW]	122

Measured values

	Week 10
Flue gas Moisture [%]	22.55
Flue gas SO2 [mg/Nm3]	97.97
Cl corroded [mg/m3]	0.008
Flue gas NOx [mg/Nm3]	63.61

Fuel blend

	Week 10
Volume [m3]	27,034
Moisture (forecasted) [wt- %]	44.1
Moisture (with full information) [wt- %]	43.9
LHV wet [MJ/kg]	9.8
S [wt- %]	0.099
Cl [wt- %]	0.022
Ash [wt- %]	3.8
N [wt- %]	0.79
S/Cl [molar]	4.65
Ca/S [molar]	4.06
Na+ K [wt- %]	0.10

Peat, stump wood and recycled wood

	Week 10
Peat [weight %]	36.1%
Peat [energy %]	39.0%
Stump wood [weight %]	15.6%
Stump wood [energy %]	18.1%
Recycled wood [weight %]	0.0%
Recycled wood [energy %]	0.0%

FuelDiet Business potential



Short and long term
fuel supply and cost
optimization € / MWh



Plant daily operation, maintenance and
consumable utilization optimization € / ton



Flue gas emission
management
optimization € / ton



Ash quality and cost
optimization € / ton



Component lifetime
optimization € / a

- Soft sensor based realtime FuelDiet enables to choose the "suitable" fuel and production cost for the asset



Jaani Silvennoinen
Tuotepäällikkö, FuelDiet® ratkaisut
Suorituskyky palvelut
jaani.silvennoinen@valmet.com
+358 40 709 2019